



CALAMBA WATER DISTRICT

Lakeview Subdivision Halang Calamba City, Laguna
 Tel. Nos. (049) 545-1614; 545-2728; 545-7895; 545-1389; 545-7981; 545-2863
 Fax: (049) 545-9752

REQUEST FOR QUOTATION

Company Name : _____ Date: _____
 Address : _____ Quotation No. CWD 28-2017
 _____ End-User: Production Department
 Tel. No./Fax No. : _____
 T.I.N. : _____

Please quote your lowest price on the item(s) listed, subject to the Terms and Condition stated below and in a sealed envelope submits your quotation duly signed by authorized representative;

Activities	Date and Time	Place / Venue
Opening of Requests for Quotation	July 4, 2017, 9:00AM	2 nd floor CWD Warehouse Building, Lakeview Subdivision, Barangay Halang Calamba City

ENGR. JOSELITO A. GILLERA

BAC Chairman

TERMS AND CONDITIONS:

1. ALL ENTRIES SHALL BE TYPEWRITTEN
2. COMMENCEMENT SHALL BE FOR A PERIOD OF ONE TO FOUR WEEKS UPON RECEIPT OF THE APPROVED PURCHASE ORDER.
3. PRICE VALIDITY SHALL BE FOR A PERIOD OF THIRTY (30) CALENDAR DAYS
4. THE APPROVED BUDGET FOR THE CONTRACT IS AMOUNTING TO **Php 291,606.13**
(BID EXCEEDING THE ABC SHALL BE AUTOMATICALLY DISQUALIFIED)

DOCUMENTARY REQUIREMENTS SHALL BE ATTACHED UPON SUBMISSION OF THE QUOTATION:

1. PHILGEPS REGISTRATION CERTIFICATE OR REGISTRATION NUMBER
2. MAYOR'S/BUSINESS PERMIT
3. INCOME AND BUSINESS TAX RETURNS (VAT PAYMENT) LATEST SIX (6) MONTHS
4. OMNIBUS SWORN STATEMENT

Item no.	ITEM & DESCRIPTION/ TECHNICAL SPECIFICATION	QTY.	UNIT AMT.	TOTAL AMOUNT
1	INSERTION ELECTROMAGNETIC FLOWMETER (INSERTION TYPE) SPECIFICATIONS: Probe: to suit to existing pipe 800mm (32 in.) nominal bore Cable wire approximate at 20-meters length			Php 291,606.13

<p>Protection IP68/NEMA6 (Indefinite submersion down to 10m [30ft])</p> <p>Weight <3.5kg 97.7lb)</p> <p>Accuracy Velocity ±2% of rate or ±2mm/s (±0.08 in./s) whichever is the greater</p> <p>Volume Refer to ISO 7145-1982 (BS1042 section 2.2) for details</p> <p>Flow condition Fully developed profile in accordance with ISO 7145 (BS 1042 section 2.2)</p> <p>Pressure Limitation 20bar (295psi)</p> <p>Power Supply Battery Life @ 0-50°C 1 battery typical 1 year 2 batteries typical 2.5 years External Battery Pack typical 5 years ----nothing follows----</p>				
---	--	--	--	--

Brand and Model : _____
Delivery Period : _____
Warranty : _____
Price Validity : _____

After having carefully read and accepted your General Conditions, I/We quote on the item(s) at prices noted above.

Printed Name/Signature/Date

Tel. No. /Cellphone No./ e-mail address