

SUPPLEMENTAL/ BID BULLETIN

Republic of the Philippines
Calamba Water District
Lakeview Subd, Halang, Calamba City
Tel. Nos: (049) 545-2728; 545-1614; 545-1389
Fax No: (049) 545-9752/502-7108
E-mail add: cwd_bac@yahoo.com

ADDENDUM NO. 1

19 April 2021

AMENDMENTS TO BIDDING DOCUMENTS

Under SECTION I. Invitation to Bid – Paragraph 2, SECTION VI. Schedule of Requirements, and SECTION VII. Technical Specifications – Material Specifications A.1.3 thereof should be read as follows:


- I. SECTION I. Invitation to Bid – Paragraph 2
 2. The **CALAMBA WATER DISTRICT** now invites bids for the above Procurement Project. Delivery of the Goods is required by **Sixty (60) to Seventy-Five (75) Days upon receipt of Purchase Order**. Bidders should have completed, within **one (1) year** from the date of submission and receipt of bids, a contract similar to the Project. The description of an eligible bidder is contained in the Bidding Documents, particularly, in Section II (Instructions to Bidders).
- II. SECTION VI. Schedule of Requirements

| Item Number | Description | Quantity | Units | Delivered, Weeks/Months |
|--------------------------------|--------------------------------|----------|-------|---|
| Supply and Delivery of: | | | | |
| 1 | 12mmø (1/2") HDPE Pipe, SDR 11 | 15 | rolls | Sixty (60) to Seventy-Five (75) Days upon receipt of Purchase Order |
| 2 | 20mmø (3/4") HDPE Pipe, SDR 11 | 10 | rolls | |
| 3 | 25mmø (1") HDPE Pipe, SDR 11 | 12 | rolls | |
| 4 | 50mmø (2") HDPE Pipe, SDR 11 | 6 | rolls | |
| 5 | 75mmø PVC Pipes, C-150 | 5 | pcs | |
| 6 | 100mmø PVC Pipes, C-150 | 82 | pcs | |
| 7 | 150mmø PVC Pipes, C-150 | 92 | pcs | |
| 8 | 250mmø PVC Pipes, C-150 | 4 | pcs | |
| 9 | 300mmø PVC Pipes, C-150 | 4 | pcs | |

III. SECTION VII. Technical Specifications – Material Specifications A.1.3

A.1.3. Rating – All service tubing shall be rated for use with water at 23.0°C (73.40°F) and at a minimum working pressure of 1.1 MPa (160 psi). Other requirements shall be in accordance with ASTM D2737/ISO 4427.

For guidance and information of all concerned.


ENGR. JOSELITO A. GILLERA
BAC Chairman

Received by: _____

Date: _____

Supply and Delivery of Various HDPE and UPVC Pipes (CWD 22-2021)