

SUPPLEMENTAL/ BID BULLETIN

Republic of the Philippines
Calamba Water District
Lakeview Subd, Halang, Calamba City
Tel. Nos: (049) 545-2728; 545-1614; 545-1389
Fax No: (049) 545-9752/502-7108
E-mail add: cwd_bac@yahoo.com

ADDENDUM NO. 1
December 28, 2023

AMENDMENTS TO BIDDING DOCUMENTS

Under Section VI. Schedule of Requirements and Section VII. Technical Specifications, Item No. 3, Submersible Pump 3 Way (Portable) should be read as follows:

I. Section VI. Schedule of Requirements


The delivery schedule expressed as weeks/months stipulates hereafter a delivery date which is the date of delivery to the project site.

Item No.	Item Description	Qty.	Unit	Delivered, Week/Months
Supply and Delivery of the following/s;				<i>Within One (1) Month upon Receipt of Purchase Order</i>
1	Submersible Motor 50 HP, 460 volts, 3 Phase	2	Unit	
2	Submersible Motor 40 HP, 230/460 volts, 3 Phase	1	Unit	
3	Submersible Pump 3 Way (Portable)	1	Unit	

II. Section VII. Technical Specifications. Item No. 3 Submersible Pump 3 Way (Portable)

HP	1.5 HP
Voltage:	220V Single Phase
Capacity/lps	9.75 lps
Body/Housing	Cast Iron
Head	6.0 meters
Speed	1800 rpm
Shafting	Stainless Steel
Shaft Seal	Mechanical Seal
Motor	Squirrel, Submersible induction pipe

For guidance and information of all concerned.


MR. EDWIN L. CARTAGO
BAC Chairperson

Received by: _____
Date: _____

Supply and Delivery of Various Submersible Pump and Motors with Complete Accessories (CWD 73-2023)