

SUPPLEMENTAL/ BID BULLETIN

Republic of the Philippines
Calamba Water District
Lakeview Subd, Halang, Calamba City
Tel. Nos: (049) 545-2728; 545-1614; 545-1389
Fax No: (049) 545-9752/502-7108
E-mail add: cwd_bac@yahoo.com

ADDENDUM NO. 1

23 February 2021

AMENDMENTS TO BIDDING DOCUMENTS

Under SECTION I. Invitation to Bid – Paragraph 2, SECTION II. Instruction to Bidders – Clause 5.3, 10.2, and SECTION III. Bid Data Sheet – Clause 5.3 and 20.2 thereof should be read as follows:

I. SECTION I. Invitation to Bid – Paragraph 2

2. The **CALAMBA WATER DISTRICT** now invites bids for the above Procurement Project. Delivery of the Goods is required by **within Three (3) Months**. Bidders should have completed, within **three (3) years** from the date of submission and receipt of bids, a contract similar to the Project. The description of an eligible bidder is contained in the Bidding Documents, particularly, in Section II (Instructions to Bidders).

II. SECTION II. Instruction to Bidders – Clause 5.3, 10.2

- 5.3 Pursuant to Section 23.4.1.3 of the 2016 revised IRR of RA No.9184, the Bidder shall have an SLCC that is at least one (1) contract similar to the Project the value of which, adjusted to current prices using the PSA's CPI, must be at least equivalent to:
- a. For procurement where the Procuring Entity has determined, after the conduct of market research, that imposition of either (a) or (b) will likely result to failure of bidding or monopoly that will defeat the purpose of public bidding: the Bidder should comply with the following requirements: *[Select either failure or monopoly of bidding based on market research conducted]*
- i. Completed at least two (2) similar contracts, the aggregate amount of which should be equivalent to at least **fifty percent (50%) in the case of non-expendable supplies and services or twenty-five percent (25%) in the case of expendable supplies]** of the ABC for this Project

10. Documents comprising the Bid: Eligibility and Technical Components


- 10.2 The Bidder's SLCC as indicated in ITB Clause 5.3 should have been completed within **three (3) years** prior to the deadline for the submission and receipt of bids.

III. SECTION III. Bid Data Sheet – Clause 5.3 and 20.2

5.3	For this purpose, contracts similar to the Project shall be: a. Supply, Installation, Testing and Commissioning of Pressure Transmitter Control System / Instrumentation Pressure Control and Electrical System b. completed within Three (3) Years prior to the deadline for the submission and
-----	--

	<p style="text-align: center;">receipt of bids.</p> <p>20.2 <i>The Lowest Calculated Bid shall submit ALL of the following post-qualification requirements:</i></p> <ol style="list-style-type: none"> 1. <i>Photocopy of Single Largest Completed Contract or Purchase Order, which should be signed by both parties.</i> 2. <i>The corresponding proof of completion, which could either be:</i> <ol style="list-style-type: none"> i. <i>Certificate of final acceptance/completion from the bidder's client; or</i> ii. <i>Official receipt of sales invoice of the bidder covering the full amount of the contract</i> 3. <i>Latest six (6) month's income tax returns filed and paid through the BIR Electronic Filing and Payment System (eFPS) covering the period of September 2020 to February 2021</i> 4. <i>Latest six (6) month's business tax returns (VAT Payments) filed and paid through the BIR Electronic Filing and Payment System (eFPS) covering the period of September 2020 to February 2021</i> 5. <i>Present and Previous Supplier of Calamba Water District must secure a Certificate of Completion on the Delivery of Contract for Goods within Five (5) Years if applicable.</i> 6. <i>Copy of Attorney's Roll Numbers who notarized the documents including the address and telephone numbers of Notary Public if there is any.</i> 7. <i>Notarized authorization to the Calamba Water District-Bid and Awards Committee, Technical Working Group for the verification of the following at the BIR Office (Regional Office) attached with photocopy of two (2) valid Identification Cards with signature of the signatory;</i> <ul style="list-style-type: none"> • <i>Latest Income and Business Tax Return (VAT Payment) within the last six months preceding the date of bid submission, and</i> • <i>Payment Confirmation</i>
--	--

For guidance and information of all concerned.


ENGR. JOSELITO A. GILLERA
 BAC Chairman

Received by: _____

Date: _____

Supply of Labor and Materials of Pressure Transmitter Control System of Laguna Hills and Woodlands Pumping Stations located at Brgy. Pansol and Putinglupa respectively (Rebidding) (CWD 07-2021)