



CALAMBA WATER DISTRICT

Lakeview Subd., Malang, Calamba City
Tel. No. 545-2863; 545-1614; 545-2728; 545-7895
545-1389; 545 7981; Fax No. 545-9792



150mm² diameter stranded cable wire

Construction:

Conductor : Annealed copper stranded wire
Insulation : Polyvinyl Chloride type PVC/C
Classification : Maximum temperature 70 °C

Dia. of conductor (max)	Conductor type	Nominal thickness of insulation	Overall Diameter (min-max)	Min. insulation resistance @ 70 °C
16.2mm	Class 2	1.8mm	17.3 - 20.9mm	0.0032MΩ.km

Prepared by:

Pedro M. Estalar
Sr. Water Utilities Mngt. Officer

Certified true and correct

MARIA CARMELA M. ELEPAÑO
OIC-Production Manager C.
Production Department