



Calamba Water District

Lakeview Subdivision, Balang, Calamba, Laguna
Tel. Nos. 545-2883, 545-1614, 545-7895, 545-1889
Tel./Fax. (049) 545-9752

Assorted submersible Cable Specification

**THERMOPLASTIC HEAT- AND MOISTURE- RESISTANT WIRE (THW),
600 VOLTS, 75 °C**

| Size of Conductor | | No. & Nominal Dia. of Wire | Wall Thickness | Approximate Overall Diameter |
|-------------------|--------|-------------------------------|-------------------|------------------------------------|
| 60mm ² | 2/0mcm | 19 x 39 x .32mm | 2.0mm | 39mm |
| 50mm ² | 1/0mcm | 19 x 33 x .32mm | 2.0mm | 37.3mm |
| 38mm ² | 1mcm | 19 x 25 x .32mm | 2.0mm | 34.5mm |
| 30mm ² | 2mcm | 7 x 53 x .32mm | 1.6mm | 30.61mm |

Description

Double jacketed round, 3-Conductor submersible cable rope-lay stranded flexible copper wires, PVC insulated, multi-conductor.

Prepared by :


Pedro M. Estalar

Sr. Water Utilities Mngt. Officer

Certified Thru & Correct


MARIA CARMELA M. ELEPAÑO

OIC-Department Manager C.

Production Department