

SUPPLEMENTAL/ BID BULLETIN

Republic of the Philippines
Calamba Water District
Lakeview Subd, Halang, Calamba City
Tel. Nos: (049) 545-2728; 545-1614; 545-1389
Fax No: (049) 545-9752/502-7108
E-mail add: cwd bac@yahoo.com

ADDENDUM NO. 1

June 11, 2024

AMENDMENTS TO BIDDING DOCUMENTS

Under Section I. Invitation to Bid. Item Nos. 5, 12, 13. Section VI. Schedule of Requirements. Item Nos. 5, 12, 13 and Section VII. Technical Specifications for Item No. 13 for Lot 1 should be read as follows:

I. Section I. Invitation to Bid. Item Nos. . 5, 12, 13

| Item No. | Items/Description | Qty. | Unit | Unit Cost | Total Amount |
|--|---|------|------|-----------|--------------|
| <i>Supply and Delivery of the following/s;</i> | | | | | |
| LOT 1 | | | | | |
| 5 | Entrance Cap 2" (Electrical) | 5 | pc. | 242.00 | 1,210.00 |
| 12 | Plastic Gate Valve 3/4" for chlorination use (HDPE) | 50 | pc. | 500.00 | 25,000.00 |
| 13 | Pressure Gauge 2" 150psi with Bushing 3/8 x 1/2 " | 50 | pc. | 622.908 | 31,145.40 |

II. Section VI. Schedule of Requirements. Item Nos. 5, 12, 13

| Item No. | Items/Description | Qty. | Unit | Delivered, Weeks/Months |
|--|---|------|------|--|
| <i>Supply and Delivery of the following/s;</i> | | | | |
| LOT 1 | | | | |
| 5 | Entrance Cap 2" (Electrical) | 5 | pc. | Within One (1) week to Four (4) Weeks upon receipt of Purchase Order |
| 12 | Plastic Gate Valve 3/4" for chlorination use (HDPE) | 50 | pc. | |
| 13 | Pressure Gauge 2" 150psi with Bushing 3/8 x 1/2 " | 50 | pc. | |

III. Section VII. Technical Specifications. Item No. 13 Pressure Gauge with Bushing for Lot 1

Material : Steel Black
Movement : Copper Alloy
Standard : ASME B40.100 Grade B, EN 837-1 & ISO 7
Measuring : Bourdon Type, C Type, or Helical Type
Connection Location: Lower Mount
Window : Plastic, Crystal Clear, snap lifted in case

For guidance and information of all concerned.


MR. EDWIN L. CARTAGO
BAC Chairperson

Received by: _____
Date: _____