



Calamba Water District

Lakeview Subdivision, Halang, Calamba, Laguna
 Tel. Nos. 545-2863, 545-1614, 545-7895, 545-1389
 Tel./Fax. (049) 545-9752

PIPE CHARACTERISTIC

- a) SQUARE THREADS TO ENSURE HIGH PRESSURE LOAD HOLDING CAPACITY,
- b) RUBBER SEAL ARE PROVIDED WITH THREAD FOR NO LEAK EVEN HIGH PRESSURE,
- c) PIPES ARE 3-METERS LENGTH AND LIGHT WEIGHT,
- d) PIPES AND THREAD ARE LONG LIFE AND CORROSION RESISTANT

PIPES SPECS.

PIPE TYPE	OUTSIDE DIA. (MM)		WALL THICKNESS AT ENDS (mm)		WALL THICKNESS AT CENTER (mm)		LENGTH	NET KG. APPROX PER PIPE
	Min.	Max.	Min.	Max.	Min.	Max.		
2 INCH DIA.								
CLASS B/STANDARD TYPE	59.80	60.10	6.00	6.20	3.80	4.00	3050	3.95
3 INCH DIA.								
CLASS B/STANDARD TYPE	87.70	88.20	7.00	7.20	4.80	5.10	3050	6.95

TOP AND BOTTOM

SIZES (INCH) Dia.	MATERIALS OF CONSTRUCTION
2" and 3" Diameter	stainless Steel 304

Prepared by:

[Signature]
Pedro M. Estalar
 Water Maint. Head

Certified true and correct

[Signature]
Engr. Elizaldy O. Novillos
 Division Manager C.

Approved by:

[Signature]
Engr. Joselito A. Gillera
 Production Department Manager