

SUPPLEMENTAL/ BID BULLETIN

Republic of the Philippines
Calamba Water District
Lakeview Subd, Halang, Calamba City
Tel. Nos: (049) 545-2728; 545-1614; 545-1389
Fax No: (049) 545-9752/502-7108
E-mail add: cwd_bac@yahoo.com

ADDENDUM NO. 1

24 August 2026

AMENDMENTS TO BIDDING DOCUMENTS

- I. Under Section III. Bid Data Sheet, ITB Clause 27.1. Item Nos. 13, 14 and 15. Under Section VII. Technical Specifications, Submersible Pump (coupled to motors), thereof should be read as follows;

- I. Section III. Bid Data Sheet, ITB Clause 27.1, should be read as follows;

Bid Data Sheet

ITB Clause	
27.1	<i>The Lowest Calculated Bid shall submit ALL of the following post-qualification requirements:</i> 13. Certificate of Manufacturer's Distributorship 14. ISO Certificate 14001:2015 15. ISO Certificate 9001:2015

- II. Section VII. Technical Specifications, Submersible Pumps (coupled to motors), should be read as follows;

Submersible Pumps (coupled to motors)

Submersible Pump (Coupled with ff motor)	Pump Model / Equivalent Model	Discharge	Total Dynamic Head (TDH) in meters	Connection
100 HP	SP 95-8	95 m ³ /hr	170	Rp 5
50 HP	SP 60-13	60 m ³ /hr	175	Rp 4

For guidance and information of all concerned.


ENGR. JOSELITO A. GILLERA
BAC Chairperson

Received by: _____

Date: _____

Supply and Delivery of Submersible Pumps and Motors (CWD 50-2026)